

Solicitation VA250-15-B-0011

Replace Work Therapy Greenhouse; 538-13-103

#### Question and Answers

1. Please provide specification section for “ PMSC51 “ indicated on Drawing E601 single line diagram , also indicated as 15KV Load Bank Cabinet with detail on Drawing ES102

*Answer: No spec section was provided for the 15KV load bank cabinet. Details on drawings.*

2. Please clarify scope of work intended for (2) ceiling speakers indicated on Drawing ET101 : specifications section , wiring new or existing to where?

*Answer: The contractor is to disregard the paging speaker symbols for the new building. Paging functions will be handled through the fire alarm system. Revised drawing sheets E001 and ET101 dated 7/27/2015 reflect these changes (see attachments).*